



TOWN OF FOXBOROUGH
40 SOUTH STREET
FOXBOROUGH, MASSACHUSETTS 02035

Cold Water Meters IFB

ADDENDUM #2

March 24, 2022

NOTICE TO BIDDERS

1. Question- Would the town accept 316 stainless steel for the 1" - 2" meters? It is NSF/ANSI 61 certified lead-free.
 - a. No. From the IFB: All meter bodies shall be lead-free bronze containing a minimum of 85% copper.
2. Question- Could you please provide more details pertaining to the clause below:
 - Meter Test Ports -1.5" and 2" meters shall be delivered with 1" test adaptor attached with a length of straight pipe a minimum of 3 pipe diameters from meter.
 - Is the town looking for the 1.5" and 2" meters to include an additional spool piece with a test port?
 - a. YES, the 1.5-in and 2-in meters are to include an additional spool piece with a test port
3. Question- What wire length coming out of the meter is the town looking for?
 - a. 25'
4. Question- Is the town requiring the meter to come with the Itron in-line connector? Or, is a pig-tail end acceptable?
 - a. Itron Inline Connector